

Connecting the Dots with ICS Cyber Incidents



Joe Weiss, PE, CISM

Applied Control Solutions, LLC

(408) 253-7934

joe.weiss@realtimeacs.com



ICSJWG 2010 Spring Conference

Targeted SCADA attack - US

Insecure GIS mapping system
integration led to targeted attack

**No SCADA servers or mapping
system for two weeks**

4 Man-months to recover

Minimal forensics

No information sharing with local law
enforcement, FBI, or ES-ISAC



Plant typical of Browns Ferry and Hatch

Similar systems impacted
Inadequate policies
Inadequate design
Lack of forensics
Failsafes worked!

Same problems affected
many non-nuclear facilities



DRYWELL TORUS

GENERAL ELECTRIC

GEZ-4386

Reactor Coolant Pump

ACS
APPLIED CONTROL Solutions


Applied Control Solutions Proprietary Information

Pipeline rupture with fatalities

June 10, 1999 in Bellingham, WA
SCADA failure resulted in gasoline
discharge into two creeks and
ignited

Fireball killed three persons,
injured eight; caused significant
property damage; released
~230,000 gallons of gasoline
causing substantial environmental
damage

Previous SCADA problems
Minimal cyber forensics



DC Metro crash

June 22, 2009, two WMATA trains collide

9 fatalities; 52 injured

NTSB investigation determined the Automatic Train Protection (ATP) system failed to detect the presence of an idling train

ATP is a “vital system” provides protection against collisions and over speed conditions

Sept 22 NTSB letters cite parasitic oscillations and unintended signal paths

Lack of alarms and adequate forensics



Unintended ICS impacts

A disturbance resulted in the loss of SCADA, AGC, Network Applications and ICCP. **The disturbance was caused by the implementation of a device locking security tool. The tool caused select hard drives to become unavailable.** The tool was being implemented in response to the Critical Infrastructure Protection (CIP) standards.



From January-June 2009 NERC
Disturbance Reports



Applied Control Solutions Proprietary Information